

Boiler/Pressure Vessel Information Capture Form

20091214

Asset Number (i.e., 6-digit number from asset bar code label) Date

Instructions:

1. Complete this form - in addition to a regular Asset Capture form - for equipment that would be considered a Boiler or Pressure Vessel - use the same Asset Number on both forms.
2. Slash zeroes (this is the letter O, this is a zero Ø).
3. If you have a question, check with your Supervisor/Assistant Director.
4. Complete all known information.
5. Return the completed form to your supervisor for their review.

DO NOT send this form without your supervisor's signature indicating they have reviewed and agree to the submitted data - it will be returned!

Manager's/Supervisor's Signature

User Defined Fields:

NC Vessel #	<input style="width: 95%; height: 25px;" type="text"/>	
Boiler ID #	<input style="width: 95%; height: 25px;" type="text"/>	
National Board #	<input style="width: 95%; height: 25px;" type="text"/>	
Type	<input style="width: 95%; height: 25px;" type="text"/>	(see table below)
Use	<input style="width: 95%; height: 25px;" type="text"/>	(see table below)
Size (Cu. Ft.)	<input style="width: 95%; height: 25px;" type="text"/>	
Year Built	<input style="width: 95%; height: 25px;" type="text"/>	
Maximum Allowable Pressure	<input style="width: 95%; height: 25px;" type="text"/>	
Safety Set Pressure	<input style="width: 95%; height: 25px;" type="text"/>	
Date Certificate Expires	<input style="width: 95%; height: 25px;" type="text"/>	

Type	Use	Definition/Example
Boiler	Electric boiler	High Pressure Boiler (steam/vapor generated at > 15 psig OR water heated to > 250°F and > 160 psig)
	Miniature boiler	
	High temperature water boiler	
	High temperature liquid boiler (other than water)	
	Fire tube	
	Hot water heating boiler (normally for building heat)	Low Pressure Boiler (steam/vapor generated at ≤ 15 psig OR water heated to ≤ 250°F and ≤ 160 psig)
	Hot water supply boiler (furnishes hot water to be used externally to itself; e.g., domestic water boiler)	
	Steam heating boiler (normally for building heat)	
Pressure Vessel	Domestic water heater	Water Heater (heats potable water for external use to the system at ≤ 160 psig and ≤ 250°F)
	Air/gas storage tank	Air Compressor
	Autoclave	Sterilizer
	Water/liquid storage tank	
	Heat Exchanger	